

BOBBY JINDAL
GOVERNOR



ANGELE DAVIS
COMMISSIONER OF ADMINISTRATION

State of Louisiana
Division of Administration
Office of Risk Management

April 14, 2010

**AMENDMENT NO. 2
REVISIONS
ISSUED BY THE DIVISION OF ADMINISTRATION-
OFFICE OF RISK MANAGEMENT**

Bid Proposal No.: BM-12

FOR: Following Form Comprehensive Blanket Broad Form (Repair or Replacement Cost) Equipment Breakdown Protection Coverage for State of Louisiana Various State Departments, Agencies, Boards and Commissions

Bid Opening Date: April 21, 2010 at 10:00 A.M.

This amendment provides for clarification and additional information. **This amendment must be signed and returned.**

If you have any questions concerning this amendment, please call Kristy Breau at (225) 342-8470.

Bidder/Contractor Signature

ADDITIONAL INFORMATION

IFB Reference: PART IV GENERAL BID INFORMATION Item 2.4
Page No.: 16 OF 27

The question was posed concerning the current percentage of or amount of commission return on the expiring policy.

There is a 0% commission return included in the previously awarded bid quotation for coverage effective July 1, 2007.

CLARIFICATION

IFB Reference: PART II TECHNICAL SPECIFICATIONS Item 6.5
Page No.: 12 OF 27

The 200 hours is a combination of both Engineering and Claims Adjusting Services.

REVISION # 1

IFB Reference: PART II TECHNICAL SPECIFICATIONS Item 6.10
Page No.: 12 OF 27

The following replaces the original wording of **Item 6.10** in the original bid specifications.

6.10 The bidding company shall provide Transformer Oil Gas Analysis (TOGA) Testing as needed on transformers rated at 5000KVA and higher. Detailed reports of the finding shall be sent to the ORM, Loss Prevention Section. The rate(s) per Transformer Oil Gas Analysis (TOGA) Test shall be indicated on Exhibit II of these specifications.

One confirmed test is performed annually on the Superdome. We do not have an exact count of the total tests that may be needed each fiscal year.

REVISION #2

IFB Reference: EXHIBIT II - RATES
Page No.: 20 OF 27

The following page replaces EXHIBIT II - RATES of the original bid specifications.

EXHIBIT II

RATES

- 1) The bidder/contractor shall indicate below the rate(s) per unit of exposure corresponding to premium indicated on EXHIBIT I.

- 2) The bidder/contractor shall indicate below the hourly rate for time over the two hundred (200) hours for engineering and claims adjusting services. (For explanation refer to PART II-TECHNICAL SPECIFICATIONS, Subsection 6, Engineering, Adjusting and Inspection Services, paragraph 6.5)

- 3) The bidder/contractor shall indicate below the rate(s) per Transformer Oil Gas Analysis (TOGA) Test. (For explanation refer to PART II-TECHNICAL SPECIFICATIONS, Subsection 6, Engineering, Adjusting and Inspection Services, paragraph 6.10)